

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00132	OWNER'S NAME:	REMETO
DATE:	10/26/2015	TYPE:	Footings
TIME STARTED:	1:57 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-15-26063-0013		

	1. Foundation Drains OK.		
	2. OK to Backfill w/Drain Rock and Fabric.		
L			

INSTRUCTIONS: Provide Photos Of Drain Rock Coverage Prior to Total Backfill.

NEXT INSPECTION: Floor Framing

RE-INSPECTION FEE DUE? V NO

YES

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

ieremv.haberman @co.kittitas.wa.us

\$

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506