



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00132

OWNER'S NAME: REMETO

DATE: 5/19/2016

TYPE: Footings

TIME STARTED: 10:52 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-26063-0013

1. Rear deck pads ok
2. Bring grade up for rear footings to maintain 24" depth
3. Front footing ok
4. Will deck be concrete in front per plan? Provide engineering if changed to wood framing

INSTRUCTIONS: Ok to pour

NEXT INSPECTION: turned down patio slab? Shearwalls

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506