



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00132

OWNER'S NAME: REMETO

DATE: 7/27/2016

TYPE: Gas piping

TIME STARTED: 12:07 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-26063-0013

1. Gas at 12#. Needs to be 15# minimum for test
2. Gas line not run for back porch BBQ
3. Back porch trusses and framing ok to soffit
4. Front porch framing has changed from engineered plans. Obtain approval from engineer for change

INSTRUCTIONS: Ok to cover rear porch. Obtain approval for front porch framing change. Have gas at proper test pressure

NEXT INSPECTION: Plumb/mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506