



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00156

OWNER'S NAME: CARBARY

DATE: 5/15/2015

TYPE: Footings

TIME STARTED: 11:25 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-24050-0316

	1. Verify (2) #4 continuous in thickened footings per detail 3/S3.0 - Clouded on drawings
	2. Complete rebar installation
	3. Ok to pour once footings are complete

INSTRUCTIONS: Ok to pour when installation is complete

NEXT INSPECTION: Foundation Walls

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506