



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00156

OWNER'S NAME: CARBARY

DATE: 2/1/2016

TYPE: Mechanical and plumbir

TIME STARTED: 11:05 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-14-24050-0316

1. Gas at 15#-ok
2. DWV on stack-ok
3. H2O at 80#-ok
4. Make up air may be required for range hood
5. Fireplace not installed yet
6. Submit revision for added mechanical room in crawlspace area
7. Install fan in basement bath
8. Note: all raftered ceiling areas are not vented. Spray foam must be used
9. Heating duct ok
10. Exhaust ok

INSTRUCTIONS: Complete above, ok to call for framing

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jessica.contratto @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506