



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00156

OWNER'S NAME: CARBARY

DATE: 11/17/2016

TYPE: Final

TIME STARTED: 11:30 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-14-24050-0316

1. Fire pit not installed
2. Caulk exterior @ gas meter
3. Install grille on exterior for master exhaust
4. Install return grille in stairwell to bonus room
5. Install self closing hinges to Garage
6. Provide Mechanical room revision
7. Provide MA or submittal for range hood
8. Provide Blower Door
9. Water/Sewer Ok
10. Insulation Ok
11. Fire Final Ok
12. Plumbing Ok
13. Fireplace Final Ok

INSTRUCTIONS: Complete above

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506