



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00165

OWNER'S NAME: BV RESORT HOMES

DATE: 5/26/2016

TYPE: Framing

TIME STARTED: 11:43 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-19051-0032

1. Plumbing rough in Ok
2. Supply @ 90#/15 mins - Ok
3. DWV on stack - Ok
4. Bathroom exhaust Ok
5. HD installed @ garage entry - Correction Ok
6. A35 correction not complete - Verify @ Framing

INSTRUCTIONS: Install A35's per dwgs

NEXT INSPECTION: Framing

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506