

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00180	OWNER'S NAME:	RAGLAND
DATE:	6/23/2015	TYPE:	Rough-in plumbing
TIME STARTED:	10:26 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	18-17-01020-0006		

	1. DWV at 5#-ok		
	2. H2O at 68#-ok		
INSTRUCTIONS: rough plumbing ok			
NEXT INSPECTION: framing			
RE-INSPECTION FEE DUE? VION YES \$			
	IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION		
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
	iessica.contratto @co.kittitas.wa.us		
	 INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506 		