



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00180

OWNER'S NAME: RAGLAND

DATE: 6/24/2015

TYPE: Framing

TIME STARTED: 12:46 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-17-01020-0006

	1. Trusses OK.
	2. Attic Access Not Complete.
	3. Mechanical Venting Not Complete.

INSTRUCTIONS: Complete Above. OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506