KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00195 **OWNER'S NAME:** Bucht

DATE: 8/28/15 **TYPE:** Ext Shear

TIME STARTED: 11:01 AM **INSPECTOR:** Bennett

1	Corrections not complete / Provide engineering for stepped footing or detail for fix
2	SFR - Ext Shear OK
3	Garage - Ext Shear OK
4	OK to Cover Ext.

INSTRUCTIONS: Provide Eng. for step footing / OK to Cover Ext

NEXT INSPECTION: Mech/Plumb

RE-INSPECTION FEE DUE? ☒ NO ☐ YES $ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

justin.bennett **@co.kittitas.wa.us**