## **INSPECTION REPORT**

BP-15-00216

**PERMIT NUMBER:** 

OWNER'S NAME: CASCADE VIEW

DATE:	5/28/2015	TYPE:	Slab plumbing
TIME STARTED:	3:48 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	18-18-27071-0135		
1. DWV OK. 11#/15min.			
INSTRUCTIONS: OK to Backfill.			
NEXT INSPECTION: Thickened Footings			
RE-INSPECTION FEE	E DUE? NO YE	S	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
jeremy.haberman @co.kittitas.wa.us			
• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			