INSPECTION REPORT

PERMIT NUMBER:	BP-15-00217	OWNER'S NAME:	ANDERSON
DATE:	1/29/2016	TYPE:	Framing
TIME STARTED:	9:11 AM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	19-20-35000-0001		
 All Shear Corrections OK. Header Correction at Great Room Outstanding. Awaiting Engineers Letter. Pellet Stove Rough In Not Complete. Will see by Insulation. Mechanical Supply Ducts in Joist Bay. Correction Required. Framing OK. 			
INSTRUCTIONS: M	ake Corrections Above. OK to Ins	sulate Will See Co	rrections at Insulation Inspection.
NEXT INSPECTION:			
RE-INSPECTION FEE DUE? VES \$ IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>ieremv.haberman</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694 http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 Main Office Line: 509-962-7506			