



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00217

OWNER'S NAME: ANDERSON

DATE: 4/27/2016

TYPE: Final

TIME STARTED: 11:24 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-20-35000-0001

1. Complete front railing
2. Maintain fire separation in garage
3. Tighten up self closing man door
4. Window not safety glazed in guest bathroom
5. Smoke detector not located in Office
6. Maintain fire separation in shop
7. Verify Energy Credits @ re-inspection
8. Verify combustion air for pellet stove @ re-inspection
9. Verify blower door @ re-inspection
10. Verify insulation @ re-Inspection
11. Provide self closing door @ attic access to from living space
12. Verify Fireplace final @ re-inspection
13. Plumbing Final ok

INSTRUCTIONS: Make above corrections/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506