



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-15-00240

OWNER'S NAME: LAHAIE FAMILY

DATE: 9/24/2015

TYPE: Mechanical and plumbir

TIME STARTED: 10:33 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 17-18-07058-0004

1. Mechanical Exhaust OK.
2. MEchanical Supply OK. Confirm Truss Mechanical Mezzanine at Framing.
3. Gas Line OK. 15#/15min.
4. DWV Plumbing Not On Test.
5. Supply Plumbing Not On Test.
6. NOTE: Exterior Grade Above Foundation. Soil Backfilled Against OSB Sheeting.
7. Fireplace Rough In Not Complete.

**INSTRUCTIONS:** MAke Corrections Above. Confirm with Building Official Regarding Backfill

**NEXT INSPECTION:** Plumbing/Framing

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506