INSPECTION REPORT

PERMIT NUMBER:	BP-15-00241	OWNER'S NAME:	READ
DATE:	7/24/2015	TYPE:	Exterior shear
TIME STARTED:	10:07 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	19-16-17050-0027		
1. shear ok			
2. porch hardware verified Z-Max			
3. Note- porch framing not per plan. Will need to be addressed			
4. Note- obtain engineer approval for A35 clips on all overhang trusses in lieu of H1			
5. Note- fresh air required to all habitable rooms when using a whole house fan. Adding			
dampered fresh air inlet to forced air system is easiest at this point			
INSTRUCTIONS: ok to cover exterior. Garage shear also approved for cover. Signed off on permit card			
NEXT INSPECTION: plumb/mech			
RE-INSPECTION FEE	OUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
iessica.contratto @co.kittitas.wa.us			
■ INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 ■ 411 N. Ruby Street, Suite 2. Ellensburg, WA 98926 ■ Main Office Line: 509-962-7506			