



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00241

OWNER'S NAME: READ

DATE: 4/13/2016

TYPE: Final

TIME STARTED: 11:44 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-16-17050-0027

1. Septic installation not approved
2. Seal exterior penetrations @ condensing unit
3. Revisions can not be verified - ceiling installed
4. Hot tub installed - verify permit has been issued
5. Range hood not installed
6. Fireplace not functional
7. Smoke detector needed in bonus room
8. Insulation Ok
9. Plumbing Ok
10. Mechanical Ok
11. Blower door Ok
12. FLS Ok

INSTRUCTIONS: Complete above corrections/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506