



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00242

OWNER'S NAME: SHERARD

DATE: 7/9/2015

TYPE: Post holes

TIME STARTED: 10:41 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 19-16-18054-0004

	1. engineer design required for site
	2. engineer needed approval of post holes in fill
	3. compaction report needed for fill area
	4. retention of filled area required. Must be engineered retaining wall type. Exceeds 4ft
	height

INSTRUCTIONS: Do Not Pour. Complete above

NEXT INSPECTION: re-inspect

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506