



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00260

OWNER'S NAME: HANSON

DATE: 6/25/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 4:38 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 16-20-04000-0003

	1. Trusses OK.
	2. Framing OK.
	3. Plumb/Mech OK. DWV @ 5#/15/min. Supply on Live Test.

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506