

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER:	BP-15-00261	OWNER'S NAME:	BURNSTEAD
DATE:	6/26/2015	TYPE:	Footings
TIME STARTED:	12:22 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	20-15-20059-0013		

	1. unknown height of back retaining wall. Rebar and footing size needs to be verified		
INSTRUCTIONS: verify wall height and form per retaining wall schedule 1/A1. Call for re-inspection.			
Other present footings ok			
NEVT			
NEXT INSPECTION: re-inspect			
RE-INSPECTION FEE DUE? V YES \$			
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:			
	iessica.contratto@co.kittitas.wa.us		
• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 •			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			