



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

**PERMIT NUMBER:** BP-15-00261

**OWNER'S NAME:** BURNSTEAD

**DATE:** 10/1/2015

**TYPE:** Rough-in mechanical

**TIME STARTED:** 11:53 AM

**INSPECTOR:** Jeremy Haberman

**MAP NUMBER:** 20-15-20059-0013

1. Mechanical OK.
2. Fireplaces OK.
3. Plumbing Rough OK.
4. Plumbing DWV & Supply Not on Test. Will See at Framing.
5. Gas Line OK. 20#/15min.

**INSTRUCTIONS:** OK to Call for Framing

**NEXT INSPECTION:** Framing

**RE-INSPECTION FEE DUE?**  NO  YES \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ jeremy.haberman @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506