



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00261 OWNER'S NAME: BURNSTEAD  
DATE: 10/5/2015 TYPE: Re-inspection  
TIME STARTED: 10:21 AM INSPECTOR: Jeremy Haberman  
MAP NUMBER: 20-15-20059-0013

	1. Plumbing Corrections OK.
	2. Plumbing OK. DWV on Stack. Supply at 60#/15min.
	3. Trusses OK.
	4. Framing OK.
	5. Verify Shear Correction at Insulation. Holdown to be installed at P-4 Next to Fireplace

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506