



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00264

OWNER'S NAME: MCKIM

DATE: 2/10/2016

TYPE: Plumbing

TIME STARTED: 4:14 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-23052-0002

1. Plumbing Rough In OK. DWV at 5#/15min. Supply at 60#/15min. OK.

### INSTRUCTIONS:

NEXT INSPECTION: Mechanical

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: jeremy.haberman @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506