



KITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00264

OWNER'S NAME: MCKIM

DATE: 7/13/2016

TYPE: Framing

TIME STARTED: 10:23 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-23052-0002

1. Corrections ok
2. Framing ok
3. Range vent will need to be 6" minimum diameter duct

INSTRUCTIONS: Ok to insulate

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506