



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP. 15. 00291

OWNER'S NAME: Anderson

DATE: 8.11.15

TYPE: Insulation/hot tank

TIME STARTED: 11:10 am

INSPECTOR: Green

	Insulation (OF)
	① Will need manual for tankless hot water heater to verify vent termination clearances.

INSTRUCTIONS: OK to cover walls. Supply install manual.

NEXT INSPECTION: Hot vent termination clearances.

RE-INSPECTION FEE DUE? NO YES \$ 0

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:
Amber.Green @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506