



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00300 **OWNER'S NAME:** CLE ELUM ROSYLN SCHOOL DISTRICT #404
DATE: 7/28/2015 **TYPE:** Footings
TIME STARTED: 1:10 PM **INSPECTOR:** Jeremy Haberman
MAP NUMBER: 20-15-28000-0003

	1. Perimeter Footings and Perimeter A and B Pads OK.
	2. Interior Footings Not Complete at this Time Due to Sewer Location.
	3. Approved Footings Indicated in "Green" on Plan View Photo in T Drive Dated 7/28/2015

INSTRUCTIONS: OK to Pour Approved Areas Pending Special Inspectors and Structural Engineers OK.

NEXT INSPECTION: Interior Footings Or Foundation Walls.

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506