



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00300

OWNER'S NAME: CERSD

DATE: 8/6/2015

TYPE: Slab plumbing

TIME STARTED: 1:44 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 20-15-28000-0003

	1. New waste installation Ok
	2. Backfill @ your own risk
	3. System not on test
	4. Provide revised drawings for plumbing revision
	5. Place waste under test @ re-inspection

INSTRUCTIONS: Do not pour/Re-inspect waste on test

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ justin.bennett@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506