

KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## **INSPECTION REPORT**

| PERMIT NUMBER: | BP-15-00300      | OWNER'S NAME: | CLE ELUM ROSLYN SI |
|----------------|------------------|---------------|--------------------|
| DATE:          | 10/19/2015       | TYPE:         | Insulation         |
| TIME STARTED:  | 12:45 PM         | INSPECTOR:    | Jessica Contratto  |
| MAP NUMBER:    | 20-15-21030-0013 |               |                    |

| 1. Roof insulation ok  |  |  |  |
|--|--|--|--|
| 2. R-30 total rigid foam   |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
|  |  |  |  |
| INSTRUCTIONS: ok to cover when complete  |  |  |  |
|  |  |  |  |
| NEXT INSPECTION: Plumb/mech/interior shear                                       |  |  |  |
| RE-INSPECTION FEE DUE? V NO YES \$   |  |  |  |
| IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION |  |  |  |
|  |  |  |  |

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

iessica.contratto @co.kittitas.wa.us

• INSPECTION REQUEST LINE: <u>www.co.kittitas.wa.us/cds/request.asp</u> or 509-962-7694 • 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506