



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

**PERMIT NUMBER:** BP-15-00300                      **OWNER'S NAME:** CLE ELUM ROSLYN SI  
**DATE:** 11/2/2015                                      **TYPE:** Multiple (see notes)  
**TIME STARTED:** 12:14 PM                              **INSPECTOR:** Jeremy Haberman  
**MAP NUMBER:** 20-15-21030-0013

	1. Interior Shear on Upper Floor OK.
	2. Insulation OK on Upstairs Exterior Walls.
	3. Insulation on Lower Floor Interior Shearwalls OK.
	4. Framing and Blocking OK on Lower Floor Interior Shearwalls.

**INSTRUCTIONS:** OK to Cover Lower Floor Interior Shearwalls.

**NEXT INSPECTION:** Plumb/Mech/Frame

**RE-INSPECTION FEE DUE?**     NO     YES    \$ \_\_\_\_\_  
***IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION***

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:  
 \_\_\_\_\_ [jeremy.haberman@co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

• **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •  
 411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506