



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00306

OWNER'S NAME: WILLIAMS

DATE: 7/23/2015

TYPE: Footings

TIME STARTED: 10:47 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-19-01058-0001

	1. setbacks ok
	2. footings to be minimum 24" high, 1'6" to be below grade.
	3. bottom of footing to be min. 12" wide, top 18"
	4. rebar must be properly secured to prevent movement while pouring. (tied/hung with wire)

INSTRUCTIONS: Do Not Pour. Complete footings per prescriptive requirements. Handout left with homeowner . Call for re-inspection

NEXT INSPECTION: re-inspection

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ iessica.contratto @co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506