INSPECTION REPORT

PERMIT NUMBER:	BP-15-00306	OWNER'S NAME:	ALBANY RIDGE/GRAY
DATE:	12/22/2016	TYPE:	Rough-in plumbing
TIME STARTED:	12:04 PM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	21-14-09061-0010		
 Hydronics at 100# all zones H20 at 100#/15-ok DWV not on test Can mudroom sink vent go out sidewall to eliminate studor? 			
INSTRUCTIONS:			
[
NEXT INSPECTION:	DWV/mechanical		
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: <u>iessica.contratto</u> @co.kittitas.wa.us			
INSPECTION REQUEST LINE: 509-962-7694			
http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506