



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00313

OWNER'S NAME: PARDUE

DATE: 1/15/2016

TYPE: Shearwalls

TIME STARTED: 11:11 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 18-19-13000-0030

	1. H2O at 70#-ok
	2. DWV not on test
	3. Nail gable end top sheathing and check top nailing at bottom panels
	4. NE corner of north side not nailed
	5. Check nailing on 3rd sheet on east side
	6. Inspection card not on site

INSTRUCTIONS: Complete above

NEXT INSPECTION: re-inspect shear and DWV

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506