



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00313

OWNER'S NAME: PARDUE

DATE: 2/19/2016

TYPE: Mechanical and plumbir

TIME STARTED: 11:08 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 18-19-13000-0030

1. NOTE: Permit Card Not Onsite.
2. Plumbing Rough In OK. DWV at 6#/15min. Supply at 70#/15min. at Prior Inspecti on.
3. Trusses OK.
4. Framing OK.
5. Prior Shear Corrections OK.

INSTRUCTIONS: OK to Insulate.

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506