KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP.15.00321 **OWNER'S NAME:** Fortune Creek

DATE: 8.11.15 **TYPE:** Rough-Plumb

TIME STARTED: 9:50 am **INSPECTOR:** Green

	① Supply not on test.
	② Will inspect crawl once mechanical rough-in complete.
	DWV (H2O/15 min) OK

INSTRUCTIONS: Supply must be on test.

NEXT INSPECTION: Mechanical / Plumbing.

RE-INSPECTION FEE DUE? ☒ NO ☐ YES $ 0

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

Amber.Green **@co.kittitas.wa.us**