



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00343

OWNER'S NAME: KNOLL

DATE: 9/16/2015

TYPE: Slab plumbing

TIME STARTED: 12:00 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 19-15-07059-0007

	1. In Floor DWV OK. 5#/15min.
	2. Floor Drain OK.

INSTRUCTIONS: OK to Backfill.

NEXT INSPECTION: Shearwalls.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman@co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506