



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00347

OWNER'S NAME: BURNS

DATE: 11/9/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 4:08 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 17-18-15020-0003

1. Truss bracing on A07 through A12, A11 through A12, All D trusses in attic
2. DWV at 5#-ok
3. H2O at 55#-ok
4. Gas at 23#-ok
5. Add attic access over storage room upstairs
6. Framing ok

INSTRUCTIONS: See truss bracing at insulation. Ok to insulation

NEXT INSPECTION: insulation

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jessica.contratto@co.kittitas.wa.us

• **INSPECTION REQUEST LINE:** www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506