



KITTTAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00347

OWNER'S NAME: WEDDINGTON

DATE: 3/15/2016

TYPE: Final

TIME STARTED: 1:13 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 17-18-15020-0003

1. Septic Final not complete
2. Electrical cover/fixture in pool room
3. L&I sign off on electrical panel in pool room
4. Verify safety glass @ pool room windows
5. Install Smoke/CO outside of Materbedroom
6. Maintain fire separation @ garage
7. Self closing door @ garage
8. Provide temp landings @ exterior doors
9. Verify energy credits
10. Blower door Ok
11. Insulation Ok
12. Plumbing Ok
13. Fireplaces Ok
14. Verify operation of alarm @ pool door

INSTRUCTIONS: Complete above corrections/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: \_\_\_\_\_ [justin.bennett@co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506