



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00348 OWNER'S NAME: DRAIN
DATE: 12/1/2015 TYPE: Re-inspection
TIME STARTED: 10:32 AM INSPECTOR: Jessica Contratto
MAP NUMBER: 16-19-02058-0003

	1. Front SW1 panels to have 3" edge nailing
	2. BWP on sides to have 6" edge nailing
	3. Add more galvanized nails to bottom plate to meet nailing schedule

INSTRUCTIONS: complete above, re-inspect at insulation

NEXT INSPECTION: insulation/shear

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ [jessica.contratto @co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506