



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

# INSPECTION REPORT

PERMIT NUMBER: BP-15-00348

OWNER'S NAME: DRAIN

DATE: 12/4/2015

TYPE: Insulation

TIME STARTED: 12:32 PM

INSPECTOR: Jessica Contratto

MAP NUMBER: 16-19-02058-0003

	1. Shear corrections complete. Yay!
	2. Insulation ok
	3. Apply vapor barrier over insulation in residence area or use PVA primer on drywall
	4. Bring in truss sheets and drawing of revised roof framing change

**INSTRUCTIONS:** Ok to cover interior of house and exterior. Will check fire separation and door at final.  
Wait on cover for porch for approval of change in roof

**NEXT INSPECTION:** final/truss inspection for porch cover

RE-INSPECTION FEE DUE?  NO  YES \$ \_\_\_\_\_  
**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto@co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

● **INSPECTION REQUEST LINE:** [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 ●  
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 ● Main Office Line: 509-962-7506