



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00352

OWNER'S NAME: FOSTER

DATE: 10/20/2016

TYPE: Shearwalls

TIME STARTED: 12:27 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-24050-0325

1. Site Built Masonry Fireplaces Constructed Without Inspection.
2. Exterior Nailing and Holdowns OK.
3. Interior Shear Inspection Not Performed.

INSTRUCTIONS: OK to Cover Exterior. Contact Building Official Regarding Fireplaces.

NEXT INSPECTION: Plumb/Mech.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506