INSPECTION REPORT

PERMIT NUMBER:	BP-15-00352	OWNER'S NAME:	FOSTER
DATE:	6/13/2017	TYPE:	Gas piping
IME STARTED:	3:18 PM	INSPECTOR:	Jeremy Haberman
MAP NUMBER:	20-14-24050-0325		
1. Gas Piping OK. 30#/15min. OK.			
INSTRUCTIONS: OK to Back Fill			
NEXT INSPECTION:			
RE-INSPECTION FEE	DUE? V NO	YES	\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDRESS:	ieremy.haberman @	
INSPECTION REQUEST LINE: 509-962-7694 http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx			
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506			