



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00353 OWNER'S NAME: SCARSELLA
DATE: 10/20/2016 TYPE: Shearwalls
TIME STARTED: 11:15 AM INSPECTOR: Jeremy Haberman
MAP NUMBER: 20-14-24050-0214

1. NOTE: All Prior Inspections Logged to FO-15-00036. BP Set Drawings Not Available. Inspection Performed Using FO Set Drawings. Verify Compatibility at Reinspection.
2. NOTE: Site Built Masonry Fireplace Rebar Inspection Not Performed.
3. P1-3 Shearwall at Garage Not Present. Approx. 4' Wall Separating Garage Doors. Bubbled On 'FO' Set Drawings Page L2.
4. NOTE: At Contractors Request Interior Shear Inspection Not Performed at this Time.
5. Additional Nailing Required at P1-3 Shearwalls at Garage Entry. Edge Nail Spacing Not 3".
6. P1-6 Shearwalls Left and Right of Front Door Not Installed. Holdowns Not Present. Bubbled on L2 of 'FO' Set.
7. Site Built Masonry Fireplace In MAster Bedroom Constructed Without Rebar Inspection.
8. Site Built Built Masonry Fireplace In Master Bedroom Not Shown On Permit Set Drawings. Unknown Bearing.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE? NO YES \$ _____
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS: jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694
<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00353

OWNER'S NAME: SCARSELLA

DATE: 10/20/2016

TYPE: Shearwalls

TIME STARTED: 11:15 AM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-14-24050-0214

Page 2

9. P1-4 Shearwall at Master Bedroom/Bathroom Requires 4" Nailing at Exterior Portion.

10. Floor to Floor Strapping OK.

INSTRUCTIONS:

NEXT INSPECTION:

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ jeremy.haberman@co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506