



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00395

OWNER'S NAME: THE PASS

DATE: 10/17/2016

TYPE: Framing

TIME STARTED: 12:05 PM

INSPECTOR: Justin Bennett

MAP NUMBER: 22-11-04055-0013

1. Corrections not complete
2. Provide engineer ok for 4x10 used in lieu of LSL per S203C
3. Provide header confirmation for stair window
4. Provide engineer fix for rear window on S202C

INSTRUCTIONS: Complete above/Re-Inspection

NEXT INSPECTION: Re-Inspection

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [justin.bennett @co.kittitas.wa.us](mailto:justin.bennett@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506