INSPECTION REPORT

PERMIT NUMBER:	BP-15-00397	OWNER'S NAME:	THE PASS LLC
DATE:	7/7/2016	TYPE:	Slab insulation
TIME STARTED:	11:48 AM	INSPECTOR:	Jessica Contratto
MAP NUMBER:	22-11-04055-0014		
Slab insulation Hydronics in b	n and vapor barrier ok out not on test		
instructions: O	k to pour at own risk		
NEXT INSPECTION: Shearwalls			
RE-INSPECTION FEE	DUE? NO YES		\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL			
	ADDDECC: iv	occioa contratta @	co kittitas wa us

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506