



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00398

OWNER'S NAME: THE PASS LLC

DATE: 8/31/2016

TYPE: Shearwalls

TIME STARTED: 12:43 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 22-11-04055-0015

1. Exterior and Interior Shear NAiling OK.
2. NOTE: Clarity From Engineer Regarding First and Second Floor P2-2 Walls Need ed.
3. Hydronics at 100#/15min. Complete.

INSTRUCTIONS: OK to Cover Exterior at Owners Risk.

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: _____ [jeremy.haberman @co.kittitas.wa.us](mailto:jeremy.haberman@co.kittitas.wa.us)

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506