



KITITITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00398

OWNER'S NAME: THE PASS LLC

DATE: 10/12/2016

TYPE: Mechanical

TIME STARTED: 3:27 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 22-11-04055-0015

1. NOTE: Prior Corrections Not Addressed Per Contractors Request. Contractor Request Plumbing Rough In Inspection Only.
2. Gas Line OK. Gas Line at 30#/15min. OK.
3. Plumbing Rough In OK. DWV on Stack Test. Supply at 80#/15min. OK.

INSTRUCTIONS:

NEXT INSPECTION: Shear or Mechanical

RE-INSPECTION FEE DUE? NO YES \$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: jeremy.haberman @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506