



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00418

OWNER'S NAME: HOPPE

DATE: 5/27/2016

TYPE: Exterior shear

TIME STARTED: 11:39 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-14-01063-0002

1. Exterior Shear Ok
2. Provide engineer letter for HD installation
3. Ok to cover exterior
4. Revise HD installation to fall on 2 Full Height studs (multiple locations)

INSTRUCTIONS: Verify engineer letter & HD installation @ Plumb/Mech/Ok to cover exterior

NEXT INSPECTION: Plumb/Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL  
ADDRESS: justin.bennett @co.kittitas.wa.us

**INSPECTION REQUEST LINE: 509-962-7694**

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506