



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00418

OWNER'S NAME: HOPPE

DATE: 7/26/2016

TYPE: Plumbing

TIME STARTED: 11:36 AM

INSPECTOR: Justin Bennett

MAP NUMBER: 19-14-01063-0002

1. Supply @ 80#/15 mins - Ok
2. DWV @ 5#/15 mins Ok
3. Plumbing rough in Ok
4. Corrections not complete
5. Soffits Ok
6. Ok to covdr soffits @ Front & Rear porchess

INSTRUCTIONS:

NEXT INSPECTION: Mech

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL
ADDRESS: justin.bennett @co.kittitas.wa.us

INSPECTION REQUEST LINE: 509-962-7694

<http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx>

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506