INSPECTION REPORT

PERMIT NUMBER:	BP-15-00513	OWNER'S NAME:	MACDONALD
DATE:	7/19/2016	TYPE:	Final
TIME STARTED:	2:21 PM	INSPECTOR:	Justin Bennett
MAP NUMBER:	16-19-05000-0008		
 Permit not on site Anchoring product data not on site Panels installed prior to anchoring & racking inspection Verify L&I inspection 			
INSTRUCTIONS: Remove (2) panels from the top and bottom for racking inspection/Provide product data for inspection/Provide permit/Re-Inspection			
NEXT INSPECTION: Re-Inspection			
RE-INSPECTION FEE			\$
IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION			
	QUESTIONS? PLEASE CONTACT THE I ADDRESS:	NSPECTOR AT THE FO <u>iustin.bennett</u> @	

INSPECTION REQUEST LINE: 509-962-7694

http://www.co.kittitas.wa.us/cds/building/inspection-request.aspx
411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506