



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

INSPECTION REPORT

PERMIT NUMBER: BP-15-00518

OWNER'S NAME: BECKER

DATE: 11/24/2015

TYPE: Frame-Plumb-Mech

TIME STARTED: 1:26 PM

INSPECTOR: Jeremy Haberman

MAP NUMBER: 20-15-29050-0132

| | |
|--|---|
| | 1. Deck Framing to Be Seen Later. |
| | 2. Plumbing Rough In OK. DWV at 5#/15min. OK. Supply at 80#/15min. OK. |
| | 3. Mechanical OK. |
| | 4. IN LEU OF VENTED WINDOWS PASSIVE AIR INLETS REQUIRED PRIOR TO FINAL. |
| | 5. Trusses OK. Framing OK. |
| | 6. Gas Line at 25#/15min. OK |
| | |
| | |
| | |
| | |
| | |
| | |
| | |
| | |

INSTRUCTIONS: OK to Insulate

NEXT INSPECTION: Insulation.

RE-INSPECTION FEE DUE?



NO



YES

\$ _____

IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

_____ jeremy.haberman @co.kittitas.wa.us

• INSPECTION REQUEST LINE: www.co.kittitas.wa.us/cds/request.asp or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506