



KITTITAS COUNTY COMMUNITY DEVELOPMENT SERVICES

## INSPECTION REPORT

PERMIT NUMBER: BP-15-00553

OWNER'S NAME: NASH

DATE: 12/9/2015

TYPE: Exterior shear

TIME STARTED: 11:14 AM

INSPECTOR: Jessica Contratto

MAP NUMBER: 20-15-29050-0041

	1. Exterior shear ok
	2. Strap at back french door in wrong spot. Hold down retrofitted. Obtain engineer approval
	I
	3. Interior shear ok

INSTRUCTIONS: Ok to cover exterior

NEXT INSPECTION: Slab insulation/hydraulics

RE-INSPECTION FEE DUE?



NO



YES

\$ \_\_\_\_\_

**IF REQUIRED, RE-INSPECTION FEES MUST BE PAID PRIOR TO SCHEDULING A RE-INSPECTION**

QUESTIONS? PLEASE CONTACT THE INSPECTOR AT THE FOLLOWING E-MAIL ADDRESS:

\_\_\_\_\_ [jessica.contratto@co.kittitas.wa.us](mailto:jessica.contratto@co.kittitas.wa.us)

• INSPECTION REQUEST LINE: [www.co.kittitas.wa.us/cds/request.asp](http://www.co.kittitas.wa.us/cds/request.asp) or 509-962-7694 •

411 N. Ruby Street, Suite 2, Ellensburg, WA 98926 • Main Office Line: 509-962-7506